

**ADDENDUM #2
TO SPEC. 06-178**

**SOUTH STREET MAINTENANCE FACILITY,
PHASE II PROJECT 700797a**

Addendum #2 to Spec. 06-178 for above project, bids to be opened on Wednesday, June 14, 2006 at 12:00 noon.

Please note the attached clarification.

All other terms and conditions to remain unchanged.

Dated this 12th day of June, 2006.

Purchasing Department

Vince M. Mejer
Purchasing Agent


ADDENDUM NO. 2

SOUTH STREET MAINTENANCE FACILITY PROJECT 700797A
SPEC. NO. 06-178

TO ALL PROSPECTIVE BIDDERS:

Clarifications:

1. The steel for Phase II walls shall be epoxy coated as per the note on Sheet S-2, the majority of the walls in Phase II are for the building where the salt will be stored.
2. Item 08.0010 Reinf Stl for Steps & Retain Walls (In Place) the quantity is 23,088.00 Lbs. As stated on the Project Item Schedule.
3. Acceptable Substitution for the Modified Bitumen Roofing: GAF Materials Corp. Specification N-1-1 MGFR. (Attached page 2)



ATTACHMENT 1

SUBSTITUTION REQUEST FORM

FILE NO: 20060607-224
ARCHITECT: Vince Mejer
FIRM: City of Lincoln Purchasing
Department
K Street Complex, 440 S 8th St.,
Ste 200
Lincoln, NE 68508
PHONE: 402 441 7416
FAX: 402 441 6513

BID DATE: 6/14/2006
PROJECT: Salt Storage Building
Lincoln, NE
LANCASTER

07550 02 Modified Bitumen Roofing
Section Part Description

The undersigned requests consideration of the following:

PROPOSED SUBSTITUTION: GAF Materials Corp. Specification: N-1-1-MGFR

Attached data includes product description, specifications, performance and test data, as necessary, for evaluation of the request; applicable portions of the data are clearly identified.

The undersigned states that the following paragraphs, unless modified on attachments, are correct:

1. This proposed substitution meets or exceeds the architects specified performance requirements.
2. Maintenance and service parts will be locally available for the proposed substitution.

The undersigned further states that the function, appearance and quality of the proposed substitution are equal or superior to the specified item.

Submitted by: Tammy McDaniel

Tammy McDaniel

Firm: GAF Materials, Corp.
Address: P.O. Box 2845
Port Arthur, TX 77643

Phone: (800) 522-9224 Ext. 7429
Toll-free Fax: (877) 271-6588

<input checked="" type="checkbox"/> Accepted	<input type="checkbox"/> Accepted as noted
<input type="checkbox"/> Bid as Equal - Review Upon Award	
<input type="checkbox"/> Not Accepted	<input type="checkbox"/> Received too late
By: <i>J. H. Newcomer</i> ARCHITECT	
Date: <i>6-9-06</i>	
Remarks: <i>REC'D 6-9-06</i>	